

HEATING, VENTILATION AND AIR CONDITIONING (HVAC)

- All facility HVAC filtration systems have been upgraded to MERV-13 air filters.
- All HVAC systems run at full economizer levels as outside air conditions allow.
- Relative humidity levels of RH 40-60% are maintained.
- HVAC systems have extended operating time to enhance the ability to filter air contaminants.
- A flush cycle added to the HVAC system controls operates the system two hours before and after occupancy.
- HVAC system is checked and rebalanced to provide negative air pressure whenever possible.
- HVAC fan speeds are managed to minimize air flow circulation across groups of people.